

# Modeling the New York State Grid in EMTP

Aboutaleb Haddadi (Electric Power Research Institute)  
Hossein Hooshyar (New York Power Authority)

EMTP® Summer User Conference  
Denver CO  
July 2022



# EMTP Model



- 271 3-phase buses
- Transmission voltage levels = {765, 345, 230, 115} kVRMSLL
- Generator bus voltage = {25, 24, 22, 20, 18, 17, 16, 13.8} kVRMSLL
- 93 generators
  - Generation = 21 GW
- 139 Z-loads + 5 P-Loads
- 92 two-winding transformers
- 18 three-winding transformers
- 232 lines and cables

# EMTP Model

Summary on network devices		
Name	Number	Number of phases
Transformer: Ideal unit	324	
RLC	1278	
CP line/cable	218	654
Ideal switch	45	
L nonlinear	12	
Synchronous machine	93	279
PQ load with load-flow (LF)	15	
PQ bus	30	
PV bus	88	
Slack bus	1	
Number of load-flow network nodes	1665	
Size of the main system of load-flow equations	5662	
Control system signals	15568	
Total number of network nodes	1845	
Size of the main system of equations	2673	


# Model Verification

Power flow EMTP vs PSS/e



# Model Verification


## Dynamics EMTP vs PSS/e



# Case Study: Line Modeling

# Transmission Corridor

- The system has a corridor with  $x$  number of mutually coupled lines.
  - RTDS t-line tool limits the number of conductor with a maximum number 12, including the ground wires.
  - EMTP can model more than 60 conductors in parallel.
- **Objective:** Study error in calculated line parameters due to limited mutual line modeling capability in RTDS.
- **Approach:** Compare line parameters with:
  - Limited representation of mutual coupling
  - Full representation of mutual coupling (accurate)



# Demonstrating Results

Positive Sequence RX Comparison ( $\Omega$ /mile)		
Parameter	Limited mutual coupling model	Full mutual coupling model
R ( $\Omega$ /mile)	6.6315068E-02	6.6400137E-02
XL ( $\Omega$ /mile)	4.6931507E-01	4.6940315E-01
XC ( $\Omega$ /mile)	1.2092219E+05	1.2089610E+05
Zero Sequence RX Comparison ( $\Omega$ /mile)		
R ( $\Omega$ /mile)	5.9863014E-01	4.5616438E-01
XL ( $\Omega$ /mile)	2.0835616E+00	1.7260274E+00
XC ( $\Omega$ /mile)	4.2416438E+06	4.2280685E+06


31% error

21% error

# Impact of IBRs on System Protection - NYPA Case Study

# Impact of IBRs on NYPA System Protection

- **Objective:** Review protection schemes and identify potential protection misoperation cases due to wind parks of the NYS grid.
- **Approach:**
  - Verify the EMTP model against NYPA P&C model
  - Model protection schemes
  - Model wind parks
  - Perform fault analysis & protection system performance



Test system: A portion of the 230/115 kV NYS grid with high concentration of wind parks.

# EMTP Model Verification


- The EMTP model was cross-examined against NYPA P&C model within ASPEN.
- The results show an acceptable match.

	Model	V1		V2		V0		I1		I2		I0	
		kV	(°)	kV	(°)	kV	(°)	A	(°)	A	(°)	A	(°)
Wind park 1	ASPEN	101.7	11.4	35.2	-163.4	47.5	-168.7	299.8	2.0	0.0	106.6	0.0	0.0
	EMTP	102.6	8.5	36.6	-167.0	47.0	-169.5	322.5	-3.1	21.6	-1.0	0.0	0.0
Wind park 2	ASPEN	114.7	11.8	22.0	-163.4	29.7	-172.6	313.1	8.9	0.0	106.6	0.0	0.0
	EMTP	113.6	12.1	22.7	-168.0	22.8	-167.5	325.5	11.5	13.0	23.6	0.0	0.0
Wind park 3	ASPEN	114.7	11.8	22.0	-163.4	29.7	-172.6	295.6	10.1	0.0	106.6	0.0	0.0
	EMTP	113.6	12.1	22.7	-168.0	22.8	-167.5	308.7	12.8	12.4	25.0	0.0	0.0

# Relay Models


- Line protective relays close to IBRs were modeled.
- Relay makes & setting were obtained from NYPA P&C.
- EMTP Protection Library relay models were used.

Relay Identifier	Protection Functions
R1	21, 85-21 (POTT), 50P, 51P, 51N, 67N, 87L
R2	21, 85-21 (POTT), 50P, 51P, 51N, 67N, 87L
R3	21, 50G, 51G
R4	21, 50G, 51G




# Wind Park Model

- Manufacturer models were not available.
- Generic EMTP models were used and parameterized to match available short circuit data.



# Relay Performance Case Study



**A-B fault on 66% of the line.**  
**Distance relay cross-polarized mho element.**  
**Zone 1 element should pick up.**


■ 230 kV  
 ■ 115 kV

**Two scenarios for the corridor:  
 (i) connected (ii) disconnected**

# Demonstrating Results


Response of distance mho zone 1 under fault AG7, scenario (i):

- Distance zone 1 successfully picks up considering the additional resistive reach due to dynamic expansion of mho zone.



Response of distance mho zone 1 under fault AG7, scenario (ii):

- Distance zone 1 fails to pick up due to changed dynamic expansion characteristics under wind parks.



# Summary of Findings

Protection function	Identified Misoperation	Cause
50P	The element fails to pick up a fault within its zone of protection.	The reason is the low amplitude of fault current contribution of a nearby Type-IV WP.
51N	The element fails to pick up a ground fault within its zone of protection.	The cause is the low level of zero sequence fault current due to a nearby WP using a transformer with a high-side, Delta winding.
67N	The zero-sequence fault current is not sufficient to operate the element; the element fails to identify the direction of a forward ground fault.	The cause is the low level of zero sequence fault current due to a nearby WP using a transformer with a high-side, Delta winding.
POTT	The scheme does not pick up a fault on the protected line.	The misoperation is caused by a malfunctioning neutral polarized directional element due to which the impacted relay fails to send a permissive trip signal to the corresponding remote relay.
21	The element fails to detect a high resistance ground fault on the protected line.	The cause is the reduced resistive coverage of the mho element due to changed dynamic mho distance characteristic because of nearby Type-III WPs.